

No.C- 277/2021



OFFICE OF THE STATION OFFICER,
FIRE & RESCUE STATION,
ALAPPUZHA
Dated.26-03-2021

NO OBJECTION CERTIFICATE
(RENEWAL)

The Board headed by the Station Officer, Fire & Rescue Station, Alappuzha has inspected the Four Storeyed (G + 3) Educational Building (E-1) having a height of 14.10 meters and total plinth area of 4463.84 SQM in re-survey No: 323-1A/6, 323-1A/9, 312/16-A3, 312/16-A5, 312/16A3, 2, BL-64 in Alappuzha District under Alappuzha municipality Komalapuram Village owned by the Most Rev: Dr. Thomas Mar Kurilos, Malankara Catholic arch Diocese of Thiruvalla, Thumpoly,. Alappuzha on 26.03.21 as per NBC-2016 and recommended to renew No Objection Certificate No. B1-6990/18 dated 28-12-2018 of the Regional Fire Officer, Fire and Rescue Services, Kottayam for the occupation of the said building for one Year

2. In the circumstances, this No Objection Certificate is issued under my seal and authority for the occupation of the above building. No further construction will be allowed in the vacant spaces provided in the approved plan.

3.This department verified only the fire fighting arrangements provided in the building. It is seen that civil construction measurements were verified by local body as per their approved plan

4. This certificate is issued on the condition that the fire fighting systems installed will be kept always functional and the owner of the building should take special care to maintain the systems installed in proper working condition. This certificate is valid for one year from the date of issue. After One year the certificate must be renewed. Non renewal of the certificate within the time limit will result in loss of eligibility for insurance coverage and appropriate legal action by the local self Government / Revenue Department. All officers of and above the rank of Station Officers of the Fire & Rescue services department will have the right to inspect the building on any day/time after serving 7 days notice to ensure that the installed systems are in good working condition.

Note:- The Fire and Safety Systems in the building must be updated as by the standards of the NBC-2016 part – 4 before the next renewal i.e. 25/03/2022

To,
The Party



Station Officer,
Fire & Rescue Station,
Alappuzha



PRINCIPAL
MATHA SENIOR SECONDARY SCHOOL
THUMPOLY, ALAPPUZHA
PIN-688 007

MANAGER
MATHA SENIOR SECONDARY SCHOOL
THUMPOLY, ALAPPUZHA
PIN-688 007